UniOP

Universal Operator Panels

Installation Guide

 ϵ

UniOP[™]
Universal Operator Panel
Installation Guide
Document code MANUUNIOP22
Version 1.09
Date 03.02.2012

The contents of this manual have been checked for correctness and conformance to the described equipment, Nevertheless it is not possible to guarantee the absence of possible discrepancies. The contents of the manual are checked on a regular basis and any necessary corrections are introduced in successive versions.

Information in this document is subject to change without notice.

No part of this manual may be reproduced or transmitted in any form or by any means, electronic or mechanical, for any purpose, without the prior written permission of Exor International S.p.A

Windows is a registered trademark of Microsoft Corporation.

Copyright © 2001-2012 Exor International S.p.A. All rights reserved.

Exor International S.p.A. - San Giovanni Lupatoto VR, Italy.

Installation Guide

Contents

Introduction	1
Product Identification	2
Technical Specifications	3
Installation	12
Phisical Dimensions	12
Connections	30
Power Supply and Grounding	39
PLC Port	40
PC/Printer Port	41
AUX Port	43
Ethernet Port	45
Models without the PC/Printer Port	45
External Keyboard Port	45
Battery Replacement	46
Removing the Legends	47
Dedicated LED's	48
Usage and Safety Guidelines	49
Installation Environment	49
Installation Procedures	52
Handling the Memory Cards	53
Getting Started	54
Command Summary	55
Troubleshooting	59
Touchscreen Calibration	59

Introduction

This Installation Guide describes the main features of the UniOP operator panels. The Guide refers to the following models:

BKDC-46	Operator interface with color display
BKDR-16	Operator interface with LCD display
CP01R-04	Operator interface with LCD display
CP02R-04	Operator interface with LCD display
CP10G-04	Operator interface with LCD display
ePAD03	Low-cost operator interface with LCD display
ePAD04	Low-cost operator interface with LCD display
ePAD05	Low-cost operator interface with LCD display
ePAD06	Low-cost operator interface with LCD display
ePAD33C	Operator interface with TFT display
eTOP03	Operator interface with LCD 3"8 display
eTOP04C	Operator interface with TFT 4"3 display
eTOP05	Operator interface with TFT 5"7 display
eTOP05EB	Operator interface with TFT 5"7 display
eTOP06	Operator interface with TFT 5"7 display
eTOP06C	Operator interface with TFT 5"7 display
eTOP20C	Operator interface with TFT 7"5 display
eTOP33C	Operator interface with TFT 10"4 display
eTOP40C	Operator interface with TFT 12"1 display
eTOP50C	Operator interface with XGA TFT 15" display
ETT-VGA	Operator interface with touch and TFT color display
MD02R-04	Low-cost operator interface with LCD display
MKDG-06	Operator interface with LCD display
MKDR-04	Operator interface with LCD display
MKDR-05	Operator interface with LCD display
MKDR-16	Operator interface with LCD display

The products have been designed for use in an industrial environment in compliance with the 2004/108/EC EMC Directive.

The products have been designed in compliance with:

EN 61000-6-4 EN 55011 Class A

EN 61000-6-2 EN 61000-4-2 EN 61000-4-3 EN 61000-4-4 EN 61000-4-5 EN 61000-4-6

The installation of these devices into the residential, commercial and light-industrial environments is allowed only in the case that special in measures are taken in order to ensure conformity to EN 61000-6-3.

The products are in compliance with the Restrictions on Certain Hazardous Substances (RoHS) Directive 2002/95/EC

In compliance with the above regulations the products are CE marked.

Product Identification

The product may be identified through a plate attached to the rear cover. You will have to know the type of unit you are using for correct usage of the information contained in the guide.

An example of this plate is shown in the figure below:



eTOP33C-0050 06/08 13435 35508

H/W V S/W V product model name month/year of production serial number hardware version of the product

software version of the product

Technical Specifications

Power supply voltage DC 18 - 30 V

Power consumption

Back-up battery (1) 3 V 270mA Lithium, not rechargeable, life about 1 year, user replaceable.

model: CR2430.Change with same battery or equivalent with the work temperature of UniOP. (for eTOP04C 3V 50mAh Lithium, rechargeable,

not user-replaceable, model VL2330)

Fuse 2 A T user replaceable

(except the models CP10G-04, ePAD03/04/05/06,

MKDG-06, ePAD33C and

eTOP03/04/05/06/20/33/40/50 that are equipped

with an overcurrent protection device)

Environmental conditions

Operating temperature $0 \div +50^{\circ}\text{C}$, with the exception of EN 60068-2-14

the model indicated on note (2)

Storage temperature $-20 \div +70^{\circ}\text{C}$ EN 60068-2-14 Operating and storage humidity $5 \div 85 \%$ RH not-condensing EN 60068-2-30 Vibrations $5 \div 9 \text{ Hz}$, 7mm peak EN 60068-2-6

9 ÷ 150 Hz, 1 G

Shock 50 G, 11 ms, 3 pulses per axis EN 60068-2-27

Protection class IP65 front panel (3) EN 60529

Keyboard reliability > 3 million operations

Touch screen tecnology Resistive

Touch screen reliability > 1 million operations

Electromagnetic Compatibility (EMC)

Emitted interference Class A EN 55011 Radiated, radio-frequency, $80 \text{ MHz} \div 1 \text{ GHz}, 10 \text{ V/m}$ EN 61000-4-3

electromagnetic field immunity test $1,4\text{GHz} \div 2 \text{ GHz}, 3\text{V/m}$

 $2GHz \div 2,7 GHz, 1V/m$

Burst immunity test $\pm 2 \text{ KV DC power supply}$ EN 61000-4-4

±1 KV signal lines

Surge immunity test ± 0.5 KV DC power port (line to EN61000-4-5

earth)

 ± 1 KV signal line (line to earth)

Electrostatic discharge immunity test 8 KV (air electrostatic EN 61000-4-2 discharge) 4KV (contact electrostatic discharge) Immunity to conducted disturbances inducted by radiofrequency field $0.15 \div 80 \text{ MHz}, 12 \text{ V}$ EN61000-4-6 Voltage dips, short interruptions and voltage variations immunity test Port : AC mains; Level : EN61000-4-11 100% duration: 1 cycle and 250 cycles (50Hz); 40% duration: 10 cycles (50Hz) 70% duration: 25 cycles (50Hz) Phase : 0°-180° PC/Printer Port(1) RS-232connector D-sub 15 pin female 300 - 38400 baud PLC Port RS-232, RS-422, RS-485, C.L. 20 mA (active), connector D-15 pin male 300 - 38400⁽¹⁾ baud connector D-9 pin female (functionality can be AUX Port configured with an optional communicatin module) (1) User memory

Recipe memory (1) 16 KB / 32 KB RAM with back-up battery Hardware clock (1) Clock/Calendar with back-up battery Alarms (1) 256/1024

Historical event list (1) last 256/1024 events with back-up battery

Programming software Designer version 6

Notes:

- feature depends on the panel models; see Table 1. (1)
- for models with "B7" suffix range -20 ÷ +60°C (2) for eTOP and ePAD range $0 \div +45^{\circ}$ C
- all the installation instructions listed in the chapter 'Installation (3) Environment' must be followed in detail.

Model	BKDC-46	BKDR-16	CP01R-04
Display	16x40 STN	16x40 LCD	4x20 LCD
Backlight	color CCFL	CCFL	LED
Graphics	320x240	320x240	LED
_			-
Display dimensions (mm)	121x91	121x91	-
Diagonal (inches)	5.6"	5.6"	-
User memory	32MB	512KB	512KB
User memory expansion	-	up to 1MB	up to 1MB
Function keys	33	14	5
System keys	24	23	19
Touch screen	-	-	-
User LED's	24	11	5
System LED's	5	4	1
PC/Printer Port	YES	YES	YES
PLC Port	YES	YES	YES
AUX Port (1)	YES	YES	YES
DX Port (video input)	-	-	-
Ethernet Port	-	-	-
USB Port	-	-	-
Esternal keyboard Port	-	YES	-
Programming speed	9600-38400	9600-38400	9600-38400
Battery	YES	YES	YES
Recipe memory	32KB	32KB	16KB
Alarms	1024	1024	1024
Events list	1024	1024	256
Hardware clock	YES	YES	YES
Buzzer	-	-	-
Max current consumption on 24VDC (mA)	600	500	250
Suffix 45: dimensions WxHxD (mm) (2)	275x220x80	216x168x82	138x186x82
Suffix 50: dimensions WxHxD (mm) (3)	-	-	-
Max panel thickness (mm)	5	8	8
Weight (Kg)	1.9	1.4	1.1

Table 1 - UniOP Technical Data

CP02R-04	CP10G-04	ePAD03	ePAD04	ePAD05	ePAD06
4x20 LCD					
LED	LED	LED	LED	LED	LED
LED	LED	LED	LED	LED	LED
-	120x32	120x32	120x32	120x32	120x32
-	70x21	70x21	70x21	70x21	70x21
-	2.8"	-	-	-	-
512KB	512KB	512KB	512KB	512KB	512KB
up to 1MB	up to 1MB	-	-	-	-
16	12	4	4	9	9
18	23	7	7	10	10
16	13	5	5	10	10
1	4	4	4	4	4
YES	YES	-	-	-	-
YES	YES	YES	YES	YES	YES
YES	YES	YES	YES	YES	YES
-	-	1	1	-	-
-	-	-	-	-	-
-	-	-	-	-	-
-	-	-	-	-	-
9600-38400	9600-38400	9600-38400	9600	9600-38400	9600
YES	YES	YES	-	YES	-
16KB	16KB	16KB	-	16KB	-
1024	1024	1024	1024	1024	256
256	256	256	-	256	-
YES	YES	YES	=	YES	-
-	-	-	-	-	-
250	300	250	250	250	250
138x186x82	141x176x76	149x109x55	149x109x55	149x109x55	149x109x55
-	141x176x80	-	-	-	-
8	5	5	5	5	5
1.1	1.1	1	1	1	1

Table 1 - UniOP Technical Data

Model	ePAD33C	eTOP03	eTOP04C
Display	30x80 TFT	LCD	TFT
		monochrome	color
Backlight	CCFL	LED	LED
Graphics	640X480	320x240	480x272
Display dimensions (mm)	218X159	77X58	95.4x53.9
Diagonal (inches)	10.4"	3.8"	4.3"
User memory	32MB	512KB	2MB
User memory expansion	16MB	-	-
Function keys	12	-	-
System keys	47	-	-
Touch screen	-	YES	YES
User LED's	24	-	-
System LED's	5	-	5
PC/Printer Port	YES	-	-
PLC Port	YES	YES	YES
AUX Port (1)	YES	YES	YES
DX Port (video input)	-	-	-
Ethernet Port	-	-	YES
USB Port	-	-	YES
Esternal keyboard Port	-	-	-
Programming speed	9600-38400	9600-38400	9600-38400
Battery	YES	YES	YES
Recipe memory	32 KB	32KB	32KB
Alarms	1024	1024	1024
Events list	1024	256	256
Hardware clock	YES	YES	YES
Buzzer	YES	-	-
Max current consumption on 24VDC (mA)	1200	400	400
Suffix 45: dimensions WxHxD (mm) (2)	-	149x109x63	149x109x61
Suffix 50: dimensions WxHxD (mm) (3)	311x276x100	-	-
Max panel thickness (mm)	4	5	5
Weight (Kg)	2.7	1	1
·			

Table 1 - UniOP Technical Data

eTOP05	eTOP05EB	eTOP06	eTOP06C	eTOP20C	eTOP33C
TFT	TFT	TFT	TFT	TFT	TFT
monochrome	monochrome	color	color	color	color
LED	LED	LED	LED	CCFL	CCFL
320x240	320x240	320x240	320x240	640x480	640X480
115x86	115x86	115x86	115x86	154x116	218X159
5.7"	5.7"	5.7"	5.7"	7.5"	10.4"
32MB	32MB	32MB	64MB	64MB	64MB
-	32MB	-	Up to 64MB	Up to 64MB	Up to 64MB
1	1	1	1	1	1
-	-	-	-	-	-
YES	YES	YES	YES	YES	YES
1	1	1	1	1	1
4	4	4	4	4	4
YES	YES	YES	YES	YES	YES
YES	YES	YES	YES	YES	YES
YES	YES	YES	YES	YES	YES
-	-	-	YES	YES	YES
-	-	-	YES	YES	YES
-	-	-	YES	YES	YES
-	-	-	-	-	-
9600-38400	9600-38400	9600-38400	9600-38400	9600-38400	9600-38400
YES	YES	YES	YES	YES	YES
32KB	32KB	32KB	32KB	32KB	32 KB
1024	1024	1024	1024	1024	1024
1024	1024	1024	1024	1024	1024
YES	YES	YES	YES	YES	YES
YES	YES	YES	YES	YES	YES
600	600	500	600	1100	1200
187x147x71	187x147x83	-	-	232x187x75	-
-	187x147x95	187x147x95	187x147x95	232x187x85	287x232x95
4	4	4	4	4	4
1.4	1.4	1.4	1.4	1.6	2.25

Table 1 - UniOP Technical Data


Model	eTOP40C	eTOP50C	ETT-VGA
Display	TFT	TFT	30x80 TFT
	color	color	
Backlight	CCFL	CCFL	CCFL
Graphics	800X600	1024X768	640x480
Display dimensions (mm)	246x184	304X228	194x146
Diagonal (inches)	12.1"	15"	9.6"
User memory	64MB	64MB	512KB
User memory expansion	Up to 64MB	Up to 64MB	-
Function keys	1	1	8
System keys	-	-	3
Touch screen	YES	YES	YES
User LED's	1	1	8
System LED's	4	4	6
PC/Printer Port	YES	YES	YES
PLC Port	YES	YES	YES
AUX Port (1)	YES	YES	YES
DX Port (video input)	YES	YES	-
Ethernet Port	YES	YES	-
USB Port	YES	YES	-
Esternal keyboard Port	-	-	YES
Programming speed	9600-38400	9600-38400	9600-38400
Battery	YES	YES	YES
Recipe memory	32 KB	32 KB	32KB
Alarms	1024	1024	1024
Events list	1024	1024	1024
Hardware clock	YES	YES	YES
Buzzer	YES	YES	-
Max current consumption on 24VDC (mA)	1000	1500	700
Suffix 45: dimensions WxHxD (mm) (2)	-	-	311x220x89
Suffix 50: dimensions WxHxD (mm) (3)	337x267x95	392x307x104	-
Max panel thickness (mm)	4	4	9
Weight (Kg)	2.8	3.8	2.7

Table 1 - UniOP Technical Data

MD02R-04	MKDG-06	MKDR-04	MKDR-05	MKDR-16
4x20 LCD	8x40 LCD	4x40 LCD	4x40 LCD	16x40 LCD
1.50	0051	LED	LED	0051
LED	CCFL	LED	LED	CCFL
-	240x64	-	-	320x240
-	127x34	-	-	121x91
-	5.2"	-	-	5.6"
512KB	512KB	512KB	512KB	512KB
-	1024KB	up to 1MB	up to 1MB	Up to 1MB
9	23	16	20	16
10	24	29	18	19
-	-	-	-	-
9	24	24	26	24
2	5	5	4	5
YES	YES	YES	YES	YES
YES	YES	YES	YES	YES
YES	YES	YES	YES	YES
-	-	-	-	-
-	-	-	-	-
-	-	-	-	-
-	-	YES	YES	YES
9600-38400	9600-38400	9600-38400	9600-38400	9600-38400
YES	YES	YES	YES	YES
16KB	16KB	16KB	16KB	32KB
1024	1024	1024	1024	1024
256	256	256	256	1024
YES	YES	YES	YES	YES
-	-	-	-	-
250	400	400	350	500
195x98x82	220x176x73	311x165x89	311x111x89	311x220x89
195x98x90	220x176x85	-	-	-
8	5	9	9	9
0.9	1.2	1.9	1.8	2.5

Table 1 - UniOP Technical Data

Notes:



- (1) With optional module.
- (2) Suffix 45: for operator panel which have suffix A6, A7, 45.
- (3) Suffix 50: for operator panel which have suffix 50.

Installation


UniOP panels are designed to be mounted on the front of some type of enclosure. The bezel height, bezel width and the cut-out dimensions for each panel type are given in the following pages.

Note: remove the red BATTERY PROTECTION strip before installation

Phisical Dimensions

All measurements are given in mm, with tolerance ± 0.5 .


MD02R-04



A = 74mm 2.91" for operator panel which have suffix A6, A7, 45. 82mm 3.2" for operator panel which have suffix 50

Figure 1 - Dimensions


CP10G-04



A = 71mm 2.8" for operator panel which have suffix A6, A7, 45. 75mm 2.9" for operator panel which have suffix 50

Figure 2 - Dimensions


CP01R-04, CP02R-04




8mm 0.31"

Figure 3 - Dimensions

BKDR-16










Figure 4 – Dimensions

BKDC-46









Figure 5 - Dimensions

MKDR-05







Figure 6 - Dimensions

MKDR-04








Figure 7 - Dimensions

ePAD03, ePAD04, ePAD05, ePAD06










Figure 8 - Dimensions

eTOP03










Figure 9 - Dimensions

eTOP04C








Figure 10 - Dimensions

eTOP05





Figure 11 - Dimensions


eTOP05EB, eTOP06, eTOP06C



A = 83mm 3.2" for operator panel which have suffix 45. 95mm 3.7" for operator panel which have suffix 50

Figure 12 - Dimensions


eTOP20C




A = 75mm 2.9" for operator panel which have suffix 45. 85mm 3.3" for operator panel which have suffix 50

Figure 13 - Dimensions

eTOP33C










Figure 14 – Dimensions

eTOP40C










Figure 15 - Dimensions

eTOP50C









Figure 16 - Dimensions

MKDG-06



A = 68mm 2.8" for operator panel which have suffix A6, A7, 45. 80mm 3.1" for operator panel which have suffix 50.

Figure 17 - Dimensions

ETT-VGA, MKDR-16




Figure 18 - Dimensions

ePAD33C




Figure 19 - Dimensions

Connections

MD02R-04




Figure 20 - Connectors

CP01R-04, CP02R-04




Figure 21 - Connectors

CP10G-04




Figure 22 - Connectors

BKDR-16





Figure 23 - Connectors


MKDG-06



AUX PORT PLC PORT PC/PRINTER PORT

Figure 24 - Connectors


ePAD03, ePAD04, ePAD05, ePAD06



- 1. Power
- 2. Aux Port
- 3. PLC Port

Figure 25 - Connectors


eTOP03



- 1. Power
- 2. Aux Port
- 3. PLC Port

Figure 26 - Connectors

eTOP04C



- 1. Power
- 2. Aux Port
- 3. PLC Port
- 4. Ethernet Port
- 3. USB Port (only for



Figure 27 - Connectors

eTOP05, eTOP05EB, eTOP06





Figure 28 - Connectors

eTOP06C, eTOP20C, eTOP33C, eTOP40C, eTOP50C



- 1. Power
- 2. Aux Port
- 3. PLC Port
- 4. PC/Printer Port
- 5. Ethernet Port
- 6. USB Port (only for



Figure 29 - Connectors

MKDR-05




Figure 30 - Connectors

MKDR-04




Figure 31 - Connectors

BKDC-46




Figure 32 - Connectors

ETT-VGA, MKDR-16




Figure 33 - Connectors

ePAD33C




Figure 34 - Connectors

Power Supply and Grounding

The power supply terminal block is shown in the figure below. The terminal block is included with the panel.




Figure 35 - Power supply terminal block

Note: ensure that the power supply has enough power capacity for the operation of the equipment.

The unit must always be grounded to earth. Grounding helps limit the effects of noise due to electromagnetic interference on the control system.

Earth connection will have to be done using either either the screw or the faston terminal located near the power supply terminal block. A yellow label help identify the ground connection. Also connect to ground the terminal 3 on the power supply terminal block

The power supply circuit may be floating or grounded. In the latter case connect to ground the power source common as shown in figure 42 with a dashed line.

When using the floating power scheme, note that the panels internally connect the power commond to ground with a 1 $M\Omega$ resistor in parallel with a 4,7 nF capacitor.

The power supply must have double or reinforced insulation

The suggested wiring for the power supply is shown in figure 36.




Figure 36 - Power supply

All the electronic devices in the control system must be properly grounded. Grounding must be performed according to applicable regulations.

PLC Port

The PLC Port is used to communicate with the PLC or with another type of controller; if the panel is configured as an UniNET client, then this port may be used for the network connection.

Different electrical standards are available for the signals in the PLC port connector: RS-232, RS-422, RS-485 or Current Loop 20 mA. The cable used selects the appropriate signals. It is always necessary to use the correct cable type for on the PLC to be connected.

Note: If the proper cable is not used, communication with the PLC will not be possible.

The connector is a D-15 pin male. Pin assignment is shown in the table below.

Pin	Description
1	Frame Ground
2	RXD
3	TXD
4	+5 V output (Max 100mA)
5	GND
6	CHA-
7	CHB-
8	TX+ 20 mA
9	TX- 20 mA
10	RTS
11	CTS
12	RX+ 20 mA
13	RX- 20 mA
14	CHA+
15	CHB+




Figure 37 - PLC Port connector and pin assignment

The communication cable must be chosen for the type of device being connected.

PC/Printer Port

The function of the PC/Printer Port depends on the mode of operation of the panel.

Configuration Mode

Operation Mode, UniNET Server

Operation Mode, UniNET not active or Client node

connection to serial printer

Only RS232 signals are available on the PC/Printer Port. The connector is a D-15 pin female. Pin assignment is shown in the table below.

Pin	Description
1	Frame Ground
2	RXD
3	TXD
4	+5 V output (max 100mA)
5	GND
6	Reserved
7	Reserved
8	Reserved
9	Reserved
10	RTS
11	CTS
12	Reserved
13	Reserved
14	Reserved
15	Reserved

PC/PRINTER PORT




Figure 38 - PC/Printer Port connector and pin assignment

Use cable CA2 to connect the panel to a PC for programming. The diagram is shown in the figure below. The connector is a D-9 pin female.




Figure 39 - Programming cable CA2




Figure 40 - Programming cable CA114

When the panel is in Operation Mode and is not as a UniNET Server, you can attach a serial printer to the PC/Printer Port. The communication parameters for the printer are defined by the application program (project file)

Note: the communication cable to the printer depends on the communication interface of the printer.

AUX Port

The AUX Port is a communication port specially designed for industrial network communication. The AUX Port connector is a 9 pin D sub type. The functionality of the AUX Port depends on the optional communication module which is plugged into the unit.

Note: The pin assignment of the Aux Port connector is described in the manual of the communication module.

The procedure to mount the communication modules is the following:

- 1) turn off the unit
- 2) partially unscrew with a screwdriver the 2 screws holding the rear cover. The screws are labelled 'A' in Figure 44
- 3) remove the cover (for eTOP05/05EB/06/06C/20C/33C/40C/50C and ePAD33C lever with screwdriver on the slot on the cover's side).
- 4) plug the module in the red connectors; make sure the connectors are locked
- 5) replace the rear cover
- 6) fix the 2 screws 'A' (for eTOP05/05EB/06/06C/20C/33C/40C/50C and ePAD33C close the cover with a little pressure).
- 7) stick in the area 'B' the label describing the functionality of the AUX Port. The label is delivered with the modules




Figure 41 - Mounting the communication modules

Ethernet Port

Pin	Description
1	TX OUT +
2	TX OUT -
3	RX OUT +
4	
5	
6	RX OUT -
7	
8	



ON: Valid link has NOT been detected OFF: Valid link has been detected

Models without the PC/Printer Port

Some UniOP models, see Table 1, do not have the PC/Printer Port. The PLC Port will be referred to as the PLC/PC Port, and will be used as a programming port when the panel is in Configuration Mode. You must use a gender changer with the CA2/CA114 cable to program these units.

External Keyboard Port

Several UniOP models, see Table 1, are equipped with a connector designed to connect an external keyboard type ET-F or AT-F. The communication cable comes with the keyboards.

Battery Replacement

Some models require the use of the lithium battery for data back-up.

The following information is maintained by the battery:

- hardware real-time clock (date and time)
- event list
- recipe data

UniOP panels signal the battery status in more than one way:



- blinking of the LED indicator FAULT or FLT (when available) or with the 'Battery' field in System Menu (BATTERY OK or LOW)
- with the value of the S6 bit in the RDA

When the panel signals that the battery is low, you should replace the battery as soon as possible.

Note: Replacing the battery will cause the loss of the data maintained by the battery.

To replace the battery, follow the procedure listed below:




Figure 42 - battery replacement

- 1) turn off the power to the panel
- use a screwdriver to loose the four screws securing the block composed by the two
 metal units
- 3) remove the block
- 4) remove the battery
- 5) replace the battery with a new one

Note: CAUTION! Danger of explosion if battery is incorrectly replaced .Replace only with the same or equivalent type recommended by the manufacturer. Dispose of used batteries according to the manufaturer's instructions.

- 6) replace the block; tighten the four screws
- 7) apply power to the panel and check that battery good status is signaled.

Note: Dispose of batteries according to local regulations.



Removing the Legends

The keyboard legends can be removed in one step by grasping the exposed portion of the legend and sliding it downward.

Use the blank legends that come with the panel or other with equivalent thickness and consistency. Do not use legends thicker than ones included in the panel.

Dedicated LED's

The table below shows the name and the symbol (when available) of the LED's dedicated to special functions which may be available in the UniOP operator panels.

LED			
Name/symbol	Color	Status	Meaning
FAULT/FLT	red	OFF	No hardware problem detected; battery OK
		BLINK	Battery low
		ON	Hardware fault
DL	green	OFF	No keys are pressed and no errors
		BLINK	Communication error (not all models)
		ON	While any key is pressed (visual feedback)
?	red	OFF	No hardware problem detected
		BLINK	Battery low
		ON	Hardware fault
	green	OFF	No keys are pressed
		ON	While any key is pressed (visual feedback)
RUN / O	green	OFF	Hardware fault
		ON	Unit in operation
COM / 🕏	green	BLINK	Communication error
		ON	Communication OK
ALARM /	red	OFF	No alarms
<u>^</u>		BLINK	Alarm requires acknowledgment
		ON	Alarm active

Table 2 - Dedicated LED's

Usage and Safety Guidelines

Applicable Regulations

Regulations and recommendations have been issued in Europe covering the main safety-related issues in control systems which include operator interfaces.

EN 60204-1 lists some important guidelines applicable when using operator interfaces.

9.2.4	Suspension of safeguards
9.2.5.3	Stop
9.2.5.4	Emergency stop
9.2.5.6	Hold-to-run controls
9.2.5.7	Two-hand controls
9.4	Control function in case of failure

Do not use operator interface to directly command motors, valves or other actuators not equipped with safeguards and potentially harmful to persons or equipment in case of fault to the unit.

The units are intended to be monted on the front panel of a metallic cabinet. The service personnel, when operating directly on the powered unit, must be electrostatically discharged.

All safety related regulations must be observed

CAUTION! Don't open the panel rear cover when the power supply is applied.

Installation Environment

The equipment is not intended for continuous exposure to direct sunlight This might accelerate the aging process of the front panel film.

The equipment is not intended for installation in contact with corrosive chemical compounds. Check the resistance of the front panel film to a specific compound before installation.

Do not use tools of any kind (screwdrivers, etc.) to operate the keyboard of the panel or the touch screen.

In order to meet the front panel protection classifications, proper installation procedure must be followed:

- the borders of the cutout must be flat
- screw up each fixing screw until the plastic bezel corner get in contact with the panel.
- The cutout for the panel must be of the dimensions indicated in this manual.
- Two types of gaskes are delivered with the UniOP panels, depending on the model, rectangular or linear.

Applying the rectangular gasket

- The gasket should be applied around the cutout prepared for the panel being careful not to place it under tension
- The gasket should be replaced every time that the panel is dismounted and remounted in its place




Figure 43 - panel with rectangular gasket installation

Applying the two linear gaskets:

Thin strip:

- The gasket should be applied around the cutout prepared for the panel
- The gasket should be applied starting from the middle of the lower side being careful not to place it under tension
- The two ends of the gasket should meet without overlap
- The gasket should be replaced every time that the panel is dismounted and remounted in its place

Large strip:

- The gasket should be applied on the operator panel just behind the bezel
- The gasket should be applied starting from the 1/3 of the lower side being careful not to place it under tension
- The two ends of the gasket should meet without overlap
- The gasket should be replaced every time that the panel is dismounted and remounted in its place




Figure 44 - panel with linear gaskets installation

Installation Procedures

Place the four fixing brackets on the longer side near the corners, as shown in figure (Figure 48). Screw each fixing screw until the plastic or aluminium bezel corner get in contact with the panel.




Figure 45 – Fixing bracket position

Cleaning Faceplates

The equipment must be cleaned only with a soft cloth and neutral soap product. Do not use solvents.

Handling the Memory Cards

The SSFDC memory cards used in some of the UniOP operator panels need to be handled with care when replaced in the memory slot of the panel.




Figure 46 – SSFDC memory card

Before inserting the memory card in its slot in the panel, the contact area must be verified to be clean. Any track of contaminants such as oil or any greasy substances should be carefully removed.

Contamination on the golden contacts of the memory card, at the moment the media is inserted in the slot, may generate an insulating layer that may result in electrical contact problems with the sliding elements of the socket.

Corrosive / active chemicals may permanently damage the memory card golden surface. Any contact with such substances must be carefully avoided.

To ensure the proper operation of the memory media the contact surface of the SSFDC card should be cleaned with a soft, clean tissue.

Note: The use of any synthetic cloth could permanently damage the memory card due to electrostatic discharge.

Direct contact with the human body (fingers) with the contact area should be carefully avoided.

In case the memory card needs to be removed from the slot and carried around, it has to be kept in a special antistatic protective case.

Getting Started

UniOP panels must be programmed with the programming package Designer.

To program a panel you will have to connect the panel to a personal computer running Designer software package; the panel must be in Configuration mode to be programmed. Use the cable CA2/CA114 to connect the panel to a personal computer.

The software package Designer is a WindowsTM application and must be properly installed. The WindowsTM environment is not included in the software package Designer and must already be installed on the personal computer.

The software package can use either the communication ports COM1 or COM2 on the personal computer. Check that the Designer program is correctly configured to comunicate with the communication port to which the cable attached.

The communication parameters between the panel and the personal computer are:

speed: 9600 (models PC/Printer Port support also speeds of

19200 and 38400 baud)

parity: none stop bit: 1

The Designer software defaults to the correct parameters.

The version of the Designer being used must be compatible with the firmware version of the panel to be programmed. Call for more information on compatibility between firmware and programming software.

Command Summary

The chapter describes the keyboard commands recognized by UniOP panels. Commands are classified according to the operating modes of the unit.

Note: The standard command assignment is described in this chapter. All the commands, except those defined for Configuration Mode, can be charged, deleted and/or extended using the Keyboard Macro Editor facility of the programming software.

Some models ado not have CLEAR key on the keyboard; the corresponding function cam be done pressing the keys ← e → at the same time.

Some models are designed to be attached to an external keyboard of type ET-F or AT-F; the commands describes in this chapter are generally referring to the use of an external keyboard

All the UniOP models, have at least 4 arrow keys and the Enter key. Panels with touch screen will show system defined touch keys on the screen whenever it is required (Figure 50).




Figure 47 - Default touch keys for the panels with touchscreen

Some of the keys described in this chapter may not be available in each UniOP model. The functions associated to them may, however, be implemented using the Keyboard Macro Editor or using an alternative predefined key.

Models without numeric keypad and without touch screen allow numeric data entry using arrow keys and/or using the Keyboard Macro Editor.

Touch screen panels will show automatically a numeric keypad whenever the data entry phase is activated.

Note: the text '2 s' associated to a key means that the key has to be held for two seconds to activate the associated function.

Configuration Mode

ENTER shows the type and version of the communication driver stored in the

unit (if any)

ENTER 2 s returns to Operation Mode if a valid communication driver and a

valid project are stored in the unit (the key must be pressed for 2

seconds)

Operation Mode

scroll page up
scroll page down
previous page
next page

ENTER 2 s

O/INS

recall the Command Menu
enter Data Entry Mode
Ins

9/PRN

Prt Scr

ENABLE 2 s

6/ (-11) (2)

recall Direct Access Mode
recall Date/Time Insert Mode

Command Menu

select up
select down
select left
select right
ENTER
CLEAR (1)
select up
select down
select left
select right

System Menu

★ select up★ select down★ activate selection→ activate selection

ENTER return to Page Mode when EXT is selected

CLEAR (1) return to Page Mode

Data Entry Mode

When in Data Entry Mode the meaning of the keys changes depending on wheter a field has been selected for Data Entry or not. A field is selscted when The Data Entry procedure has been started on that field. If not field has already been selected for Data Entry, the key assignment is shown in the table below.

move to field in previous row move to field in next row

← previous field→ next fieldIns next field

0÷9 . +/- select field a numeric field for Data Entry and enter numeric value

ENTER select a field for Data Entry

CLEAR (1) cancel entry and return to Page Mode

After a field has been selected for Data Entry, the keys are interpreted as follows.

increment digit / scroll up ASCII / select message up increment digit / scroll down ASCII / select message down

move cursor left in ASCII fieldmove cursor right in ASCII field

 $0 \div 9$. +/- numeric entry

ENTER confirm entry and return to Page Mode CLEAR (1) cancel entry and return to Page Mode

Alarm Mode

previous alarm in the list next alarm in the list acknowledge current alarm

CLEAR (1) return to page Mode

9/PRN alarm list printout/cancel print Prt Alm alarm list printout/cancel print Prt Scr alarm list printout/cancel print

Event Mode

scroll up scroll down

CLEAR (1) return to page Mode

9/PRN event list printout/cancel print Prt Alm event list printout/cancel print Prt Scr event list printout/cancel print

Password Entry Mode

increment digit
decrement digit
next digit

0÷9 numeric password entry

ENTER confirm password and return to Page Mode cancel entry and return to Page Mode ESC end entry and return to Page Mode

Time and Date Set Mode

increment field value decrement field value

ENTER field select

CLEAR (1) return to Page Mode

Direct Page Selection Mode

decrement pageincrement page0÷9page number entry

ENTER confirm entry and go to selected page cancel entry and return to Page Mode

Direct Acces Mode

decrement offsetincrement offset0÷9numeric offset entry

ENTER select next, confirm offset entry

CLEAR (1) cancel numeric offset entry end return to Page Mode

T select timers
Z select counters
E select digital inputs
A select digital outputs
M select flags/merkers
ENABLE return to Page Mode

Notes:

(1) it is equivalent to the key ESC/ \Box , when available

(2) available only in the models BKDR-16, CP10G-04 and MKDG-06.

Troubleshooting

In the case it might be impossible to switch the operator panel to Configuration Mode due to problems in the start-up phase, follow the procedure described below:

- 1. Switch off the unit
- 2. Press and hold any 3 keys
- 3. Turn on the unit and hold the keys pressed until Configuration Mode will be shown on the screen.

Touchscreen Calibration

Standard calibration:

- 1. Recall Configuration Mode
- 2. Touch the CLEAR key on the screen until a small round symbol will appear on the top right corner of the screen
- 3. touch and hold the symbol until it will move to the low lef corner of the screen
- 4. touch and hold the symbol until the indication to touch the ← key will be displayed on the screen
- 5. touch and hold the key ← until the indication to touch the ▶ key will be displayed on the screen
- 6. touch and hold the key **Ψ** until the indication to touch the Enter key will be displayed on the screen
- 7. touch and hold the Enter key until the panel will switch to Operation Mode (if a valid project is loaded in the memory)

Emergency calibration.

The Emergency calibration procedure should be used in all cases when it would result not possible to go to calibration using the standard procedure.

- 1. Switch of the unit
- 2. turn on the unit
- 3. tap in the middle of the touchscreen with a frequency of about one second until the operator panel will enter the Calibration Mode
- 4. perform the standard calibration procedure.